



Project: ITB-2020-05 – Ballfield Lighting Improvements

Issue Date: 08/10/2020

Due Date: 08/17/2020 - 12:00 pm

ADDENDUM NO. 1

Intent: This addendum is issued to incorporate the following clarifications, additions, omissions, deletions, or changes into the Contract Documents prior to the date bids are due. Except as hereinafter specified, the work shall be in accordance with the drawings and/or specifications.

A signed copy of the addendum must also be included with the bid submittal.

Question, Statement and/or Response

- 1. Scope states “Furnish six (6) new LED Lamp Technology Sports Lighting Fixtures with a minimum of 500-watt LEDs at each fixture for a complete baseball/softball field lighting system. New fixtures to be installed on existing wood poles”. Does this mean that each pole has to have 6 sets of 5-500 watt LED fixture?**

No. Each pole should have a minimum light fixture cluster of at least 5 lights.

- 2. Scope states new electrical enclosure from existing pole to new lighting enclosure and underground feed to same. The current lighting controls that are located by the field in a box that is also powering irrigation and the bathroom facility, so is it correct to assume conduits and conductors can be installed from existing panel to new lighting panel location thus not having need to install new panel for irrigation and bathroom facility.**

Yes. The controls for irrigation and the bathroom facility will remain in their existing location, so a new panel is NOT required.

- 3. Is directional boring acceptable when furnishing new conductors to each pole to minimize sod disturbance?**

Yes.

Acknowledgment:

Signature and Date

Printed Name and Title

Company Name

END OF ADDENDUM NO. 1